



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : La Monte School, 337 West Second Street
PAS Project ID : P22-03205

Matrix : Drinking Water
Report Date : 4/27/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03205-01	Field Blank La Monte School	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:52	4/21/22 11:45
P22-03205-02	1. DWWC Hall By Boiler Rm	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:52	4/21/22 11:49
P22-03205-03	2. DWWC Hall By Cafeteria	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:53	4/21/22 11:53
P22-03205-04	3. KSFP Outside Wall	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:55	4/21/22 11:57
P22-03205-05	4. DWWC Hall By Rm 14	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:59	4/21/22 12:01
P22-03205-06	5. DWWC Hall By Rm 12	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:01	4/21/22 12:05
P22-03205-07	6. DWWC Hall By Rm 21	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:02	4/21/22 12:09
P22-03205-08	7. DWWC Hall By Rm 24/25	Lead	1.35 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:04	4/21/22 12:30
P22-03205-09	8. Cafeteria New	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:57	4/21/22 12:34

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2101 WHITEVILLE ROAD TONONDAWAGA, NY 08706 PHONE 732-914-1916 FAX 732-914-4616

CHAIN OF CUSTODY

Customer: Strategic Environmental
Address: 25 Butternut Lane
Bayville, NJ 08701
Phone: (732) 539-7342

School Name: LaMonte School
School Address: 337 West Second St.
Sampled By: [Signature]
Print Name: S. Bonanno
RESULTS TO: lbonses@aol.com

Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flask Sample	Filter Precoat	# Containers	Glass or Plastic	Analyst	LAB ID
Field Blank LaMonte School	9:52 am	DW	Grab			1	250 ml Plastic	Lead	P22-03205-01
1 DWNC Hall by Boiler Rm	9:52 am	DW	Grab			1	250 ml Plastic	Lead	-02
2 DWNC Hall by Cafeteria	9:53 am	DW	Grab			1	250 ml Plastic	Lead	-03
3 KSFP outside wall	9:55 am	DW	Grab			1	250 ml Plastic	Lead	-04
4 DWNC Hall by Rm 14	9:59 am	DW	Grab			1	250 ml Plastic	Lead	-05
5 DWNC Hall by Rm 12	10:01 am	DW	Grab			1	250 ml Plastic	Lead	-06
6 DWNC Hall by Rm 21	10:02 am	DW	Grab			1	250 ml Plastic	Lead	-07
7 DWNC Hall by Rm 24/25	10:04 am	DW	Grab			1	250 ml Plastic	Lead	-08
8 Cafeteria New	9:57 am	DW	Grab			1	250 ml Plastic	Lead	P22-03205-09
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB

All First Draw

PDF Std. PDF Reduc PDF Full EDD

Date/Time Preserved with HNO3

4/19/22 @ 1630

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESER 0 = Ice 1 = HCl
VATIVE 2 = H2SO4 3 = NaOH
CODES 4 = HNO3 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Received:	S. Bonanno SEC Inc.	[Signature]	PAS	4/19/22 1:47 pm
Relinquished:	Lynn Souza	[Signature]		
Received:				
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Middle School Community School, 120 East Second Street
PAS Project ID : P22-03207

Matrix :
Report Date :

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled
P22-03207-01	Field Blank M.S. Community School	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:52
P22-03207-02	1. KS Faucet Front	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:53
P22-03207-03	2. KS Faucet Side	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:53
P22-03207-04	3. DWWC Hall By Rm 119 Left	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:59
P22-03207-05	4. DWWC Hall By Rm 119 Right	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:59
P22-03207-06	5. DWWC Hall By Rm 213 Left	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 11:02
P22-03207-07	6. DWWC Hall By Rm 213 Right	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 11:02
P22-03207-08	7. DWWC Gym Outside Men's Rm Left	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 11:05
P22-03207-09	8. DWWC Gym Outside Men's Rm Right	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 11:05
P22-03207-10	9. KS Next To Gym	Lead	2.85	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 11:07
P22-03207-11	10. DWWC Cafeteria New	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:55

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with the New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. I

Drinking Water

4/27/2022

Date Analyzed
4/21/22 13:26
4/21/22 13:30
4/21/22 13:34
4/21/22 13:55
4/21/22 14:07
4/21/22 14:11
4/21/22 14:15
4/21/22 14:19
4/21/22 14:23
4/21/22 14:28
4/21/22 14:32

lance with
nmental



Director



Specialists in Drinking Water Testing Technologies in Residential, Industrial & Municipal

PRECISION ANALYTICAL SERVICES, INC.

2141 WHITEVILLE ROAD TONAWANDA, NY 14150 PHONE 732-614-1010 FAX 732-614-1010

CHAIN OF CUSTODY

MSCS

Customer: Strategic Environmental
Address: 25 Butternut Lane
Bayville, NJ 08701
Phone: (732) 539-7342

School Name: Middle School
Community School
School Address: 120 East Second St
Sampled By: [Signature]
Print Name: [Signature]
RESULTS TO: lbonses@aol.com

Sample ID Location	Date / IT Time Sampled	Matrix Code	Grab or Comp	Flask Sample	Filter Preserv	# Con- tainers	Glass or Plastic	Analyst	LAB ID
Field Blank Middle School	10:52 AM	DW	Grab			1	250 ml Plastic	Lead	P22-03207-01
1 KS faucet Front	10:53	DW	Grab			1	250 ml Plastic	Lead	-02
2 KS faucet Side	10:53	DW	Grab			1	250 ml Plastic	Lead	-03
3 DWWC Hall by Rm 119 Left	10:59	DW	Grab			1	250 ml Plastic	Lead	-04
4 DWWC Hall by Rm 119 Right	10:59	DW	Grab			1	250 ml Plastic	Lead	-05
5 DWWC Hall by Rm 213 Left	11:02	DW	Grab			1	250 ml Plastic	Lead	-06
6 DWWC Hall by Rm 213 Right	11:02	DW	Grab			1	250 ml Plastic	Lead	-07
7 DWWC Gym ^{outside} near Rm left	11:05	DW	Grab			1	250 ml Plastic	Lead	-08
8 DWWC Gym ^{outside} near Rm Right	11:05	DW	Grab			1	250 ml Plastic	Lead	-09
9 KS next to Gym	11:07 AM	DW	Grab			1	250 ml Plastic	Lead	-10
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
10 DWWC Cafeteria new	10:55	DW	Grab			1	250 ml Plastic	Lead	P22-03207-11

SAMPLES REC'D UNPRESERVED, PRESERVED IN LAB

All First Draw

PDF Std. PDF Reduc. PDF Full EDD

Date/Time Preserved with HNO3:

4/19/22 @ 16:20

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESER 0 = Ice 1 = HCl
VATIVE 2 = H2SO4 3 = NaOH
CODES 4 = HNO3 5 = Other

Refinquished:	Print Name:	Signature:	Company:	Date + Time
Received:	SB... SEC Inc.	[Signature]	AS	4/19/22 1:44 PM
Refinquished:	Lynn Souza	[Signature]		
Received:				
Refinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Lafayette School, 50 West High Street
PAS Project ID : P22-03208

Matrix : Drinking Water
Report Date : 4/27/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03208-01	Field Blank Lafayette	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:13	4/21/22 10:43
P22-03208-02	1. DWWC By Main Entrance	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:13	4/21/22 10:46
P22-03208-03	2. DWWC In Gym	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:15	4/21/22 11:00
P22-03208-04	3. KSFP By Exit	Lead	4.08	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:16	4/21/22 11:04
P22-03208-05	4. KSFP Center Sink	Lead	2.63	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:16	4/21/22 11:15
P22-03208-06	5. NS Nurse	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:18	4/21/22 11:18
P22-03208-07	6. DWWC By (Across) Rm 102	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:19	4/21/22 11:22
P22-03208-08	7. DW Rm 101 Sink	Lead	0.950 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:20	4/21/22 11:26
P22-03208-09	8. DW Rm 102	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:22	4/21/22 11:29
P22-03208-10	9. DW Rm 104	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:23	4/21/22 11:33
P22-03208-11	10. DW Rm 210 Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:31	4/21/22 11:37
P22-03208-12	11. DW Rm 208	Lead	1.79 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:32	4/21/22 11:40
P22-03208-13	12. DW Rm 209	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:33	4/21/22 11:44
P22-03208-14	13. DW Rm 206	Lead	1.94 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:34	4/21/22 11:59
P22-03208-15	14. DW Rm 207	Lead	7.13	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:35	4/21/22 12:03
P22-03208-16	15. DWWC Hall Across Rm 207	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:35	4/21/22 12:06
P22-03208-17	16. DWWC Hall Across Rm 203	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:36	4/21/22 12:10
P22-03208-18	17. DW Rm 203 Fountain	Lead	2.02	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:37	4/21/22 12:18
P22-03208-19	18. DW Rm 202 Fountain	Lead	1.79 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:38	4/21/22 12:21
P22-03208-20	19. DW Rm 201 Fountain	Lead	1.41 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:39	4/21/22 12:25
P22-03208-21	20. DW Rm 105 Add On	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 10:28	4/21/22 12:29

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2141 WHITEVILLE ROAD TOMES RIVER, NJ 08796 PHONE 732-614-1916 FAX 732-614-4619

CHAIN
OF
CUSTODY

Customer: Strategic Environmental

Address: 25 Butternut Lane

Bayville, NJ 08701

Phone: (732) 539-7342

School Name: Lafayette School

School Address: 30 West High St.

Sampled By: [Signature]

Print Name: S. Bonanno

RESULTS TO: lbonnes@aol.com

Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Plastic Sample	Filter Preserved	# Containers	Glass or Plastic	Analyte	LAB ID
Field Blank Lafayette	10 ¹³ am	DW	Grab			1	250 ml Plastic	Lead	P22-03208-01
1 DW WC by main Entrance	10 ¹³ am	DW	Grab			1	250 ml Plastic	Lead	-02
2 DW WC in Gym	10 ¹⁵ am	DW	Grab			1	250 ml Plastic	Lead	-03
3 KSFP by Exit	10 ¹⁶ am	DW	Grab			1	250 ml Plastic	Lead	-04
4 KSFP Center Sink ?	10 ¹⁶ am	DW	Grab			1	250 ml Plastic	Lead	-05
5 NS Nurse ?	10 ¹⁸ am	DW	Grab			1	250 ml Plastic	Lead	-06
6 DW WC by Room 102	10 ¹⁹ am	DW	Grab			1	250 ml Plastic	Lead	-07
7 DW Rm 101 SINK	10 ²⁰ am	DW	Grab			1	250 ml Plastic	Lead	-08
8 DW Rm 102	10 ²² am	DW	Grab			1	250 ml Plastic	Lead	-09
9 DW Rm 104	10 ²³ am	DW	Grab			1	250 ml Plastic	Lead	-10
10 DW Rm 210 SINK	10 ³¹ am	DW	Grab			1	250 ml Plastic	Lead	-11
11 DW Rm 208	10 ³² am	DW	Grab			1	250 ml Plastic	Lead	-12
12 DW Rm 209	10 ³³ am	DW	Grab			1	250 ml Plastic	Lead	-13
13 DW Rm 206	10 ³⁴ am	DW	Grab			1	250 ml Plastic	Lead	-14
14 DW Rm 207	10 ³⁵ am	DW	Grab			1	250 ml Plastic	Lead	P22-03208-15

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB

Page 1 of 2

Deliverables: PDF Std. X PDF Reduc. PDF Full EDD Date/Time Preserved with HNO3: 4/19/22 @ 16:20

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ke 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	S. Bonanno SEL Inc.	[Signature]	PAS	4/19/22 14:5pm
Received:	Lynn Souza	[Signature]		
Relinquished:				
Received:				
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Smalley School, 163 Cherry Avenue
PAS Project ID : P22-03209

Matrix : Drinking Water
Report Date : 4/21/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03209-01	Field Blank Smalley School	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:52	4/20/22 13:20
P22-03209-02	1. KSFP By Stone Room	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:54	4/20/22 13:32
P22-03209-03	2. KSFP By Exit Door	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:55	4/20/22 13:37
P22-03209-04	3. TL Faculty Room Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:56	4/20/22 13:41
P22-03209-05	4. DWWC Across From Gym	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:57	4/20/22 13:45
P22-03209-06	5. DWWC By Faculty Bathroom	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:58	4/20/22 13:49
P22-03209-07	6. DWWC Hall By Rm 8 & 7	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:59	4/20/22 13:53
P22-03209-08	7. DWWC Hall By Rm 9	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:00	4/20/22 13:57
P22-03209-09	8. DW By Rm 14 Bubbler	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:02	4/20/22 14:01
P22-03209-10	9. DW By Rm 16 Bubbler	Lead	2.24	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:03	4/20/22 14:05
P22-03209-11	10. New Gym Exit 10 Bottle Filler	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:07	4/20/22 14:18
P22-03209-12	11. New Gym Boys & Girls BR 2nd Fl.	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 09:09	4/20/22 14:34

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITEVILLE ROAD TOMS RIVER, NJ 08785 PHONE 732-814-1816 FAX 732-814-4816

CHAIN OF CUSTODY

Customer: Strategic Environmental
Address: 25 Butternut Lane
Bayville, NJ 08701
Phone: (732) 539-7342

School Name: Smalley School
School Address: 163 Cherry Ave
Sampled By: [Signature]
Print Name: J Bonanno
RESULTS TO: jbonnes@aol.com

Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Field Sample	Field Preserv	# Containers	Class or Plastic	Analyte	LAB ID
Field Blank Smalley School	8:52	DW	Grab			1	250 ml Plastic	Lead	P22-03207-01
1 KSFP by Store Room	8:54	DW	Grab			1	250 ml Plastic	Lead	-02
2 KSFP by Exit Door	8:55	DW	Grab			1	250 ml Plastic	Lead	-03
3 TL Faculty Room Sink	8:56	DW	Grab			1	250 ml Plastic	Lead	-04
4 DWWC Across from Gym	8:57	DW	Grab			1	250 ml Plastic	Lead	-05
5 DWWC by Faculty Bathroom	8:58	DW	Grab			1	250 ml Plastic	Lead	-06
6 DWWC Hall by Rm 8 + 7	8:59	DW	Grab			1	250 ml Plastic	Lead	-07
7 DWWC Hall by Rm 9	9:00	DW	Grab			1	250 ml Plastic	Lead	-08
8 DW by Rm 14 bubbler	9:02	DW	Grab			1	250 ml Plastic	Lead	-09
9 DW by Rm 16 bubbler	9:03	DW	Grab			1	250 ml Plastic	Lead	-10
10 New Gym Ext 10 Bottle Filler	9:07	DW	Grab			1	250 ml Plastic	Lead	-11
11 New Gym Bathroom 2nd floor	9:09	DW	Grab			1	250 ml Plastic	Lead	P22-03209-12
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB

All First Draw

Page 1 of 1

Deliverables:

PDF Std. X
PDF Reduc
PDF Full
EDD

Date/Time Preserved with HNO3:

4/12/22 @ 16:20

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

Relinquished:	Print Name:	Signature:	Company:	Date + Time
Received:	J Bonanno SEC Inc.	[Signature]	PAS	4/19/22
Relinquished:	Lynn Souza	[Signature]		1:46 pm
Received:				
Relinquished:				
Received:				



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Bound Brook High School, 111 West Union Avenue
PAS Project ID : P22-03210

Matrix : Drinking Water
Report Date : 4/27/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03210-01	Field Blank High School	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 07:54	4/21/22 09:39
P22-03210-02	1. DWWC Hall By Rm 18	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 07:54	4/21/22 09:43
P22-03210-03	2. DWWC Hall By Rm 21A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 07:57	4/21/22 10:07
P22-03210-04	3. DWWC Hall By Gym Door	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 07:58	4/21/22 10:11
P22-03210-05	4. DWWC Hall By Rm 30	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 07:59	4/21/22 10:15
P22-03210-06	6. KSFP Faucet Outside Wall	Lead	2.10	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:03	4/21/22 10:19
P22-03210-07	7. IM Kitchen	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:05	4/21/22 10:23
P22-03210-08	8. KSFP Between Wall & IM	Lead	2.35	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:06	4/21/22 10:27
P22-03210-09	9. DWWC Cafeteria	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:09	4/21/22 10:31
P22-03210-10	10. DWWC Hall By Rm 113	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:12	4/21/22 10:35
P22-03210-11	11. DWWC Hall By Rm 116	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:13	4/21/22 10:39
P22-03210-12	12. DWWC Hall By Rm 104	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:15	4/21/22 10:52
P22-03210-13	13. DWWC Hall By Rm 216	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:18	4/21/22 10:56
P22-03210-14	14. DWWC Hall By Rm 204	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:20	4/21/22 11:00
P22-03210-15	15. DWWC Hall By Rm 310	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:22	4/21/22 11:04
P22-03210-16	16. Trainers Rm By 23A IM	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:34	4/21/22 11:08
P22-03210-17	17. Field House IM	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:44	4/21/22 11:13
P22-03210-18	18. DWWC Field House	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:43	4/21/22 11:17
P22-03210-19	19. Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/19/22 08:44	4/21/22 11:41

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2141 WHITEVILLE ROAD TOWNSHIP, NJ 08706 PHONE 732-614-1815 FAX 732-614-4810

CHAIN
OF
CUSTODY

High School

Customer: Strategic Environmental

Address: 25 Butternut Lane

Bayville, NJ 08701

Phone: (732) 539-7342

School Name: Round Brook High School

School Address: 111 West Union Ave

Sampled By: [Signature]

Print Name: J Bonanno

RESULTS TO: jbonnes@aol.com

Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Pick Sample	Filter Present	# Containers	Class or Plastic	Analysis	LAB ID
Field Blank High School	7:54 am	DW	Grab			1	250 ml Plastic	Lead	P22-03210-01
1 DW WC Hall by Rm 18	7:54 am	DW	Grab			1	250 ml Plastic	Lead	-02
2 DW WC Hall by 21A	7:57 am	DW	Grab			1	250 ml Plastic	Lead	-03
3 DW WC Hall by Gym Door	7:58 am	DW	Grab			1	250 ml Plastic	Lead	-04
4 DW WC Hall by Rm 30	7:59 am	DW	Grab			1	250 ml Plastic	Lead	-05
5 DW Fountain Girls Locker Gym Room 23A	8:01 am	DW	Grab			1	250 ml Plastic	Lead	
6 KS FP Faucet outside wall	8:03 am	DW	Grab			1	250 ml Plastic	Lead	-06
7 IM Kitchen	8:05 am	DW	Grab			1	250 ml Plastic	Lead	-07
8 KS FP Between wall + IM	8:06 am	DW	Grab			1	250 ml Plastic	Lead	-08
9 DW WC Cafeteria	8:09 am	DW	Grab			1	250 ml Plastic	Lead	-09
10 DW WC Hall by Rm 113	8:12 am	DW	Grab			1	250 ml Plastic	Lead	-10
11 DW WC Hall by Rm 116	8:13 am	DW	Grab			1	250 ml Plastic	Lead	-11
12 DW WC Hall by Rm 104	8:15 am	DW	Grab			1	250 ml Plastic	Lead	-12
13 DW WC Hall by Rm 216	8:18 am	DW	Grab			1	250 ml Plastic	Lead	-13
14 DW WC Hall by Rm 204	8:20 am	DW	Grab			1	250 ml Plastic	Lead	P22-03210-14

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB. (22)

Page 1 of 2 All First Draw

Deliverables: PDF Std. X PDF Reduc. PDF Full EDD Date/Time Preserved with HNO3: 4/19/22 @ 16:20

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESER VATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

Refinquired:	Print Name:	Signature:	Company:	Date + Time
Received:	S Bonanno SEL Inc.	[Signature]	PAS	4/19/22
Refinquired:	Lynn Souza	[Signature]		1:47 pm
Received:				
Refinquired:				
Received:				



Specialties in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

3141 WHITEVILLE ROAD TOMES RIVER, NJ 08798 PHONE 732-914-0913 FAX 732-914-0914

CHAIN OF CUSTODY

Customer: Strategic Environmental
Address: 25 Butternut Lane
Bayville, NJ 08701
Phone: (732) 539-7342

School Name: Bond Brook High School
School Address: 111 West Union Ave
Sampled By: [Signature]
Print Name: SBonanno
RESULTS TO: lbones@aol.com

Sample ID Location	Date & Time Sampled	Matrix Code	Grab or Comp	Plastic Bottle	Filter	# Containers	Glass or Plastic	Autoclave	LAB ID
15 DWWC Hall by Rm 310	8:22 AM	DW	Grab			1	250 ml Plastic	Lead	P22-03210-15
16 Trainers Room by 23A IM	8:34 AM	DW	Grab			1	250 ml Plastic	Lead	-16
17 Field House IM	8:41 AM	DW	Grab			1	250 ml Plastic	Lead	-17
18 DWWC Field House	8:43 AM	DW	Grab			1	250 ml Plastic	Lead	-18
19 Field Blank	8:41 AM	DW	Grab			1	250 ml Plastic	Lead	P22-03210-19
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 22 of All First Draw

Deliverables: PDF Std. ☒ PDF Reduce ☐ PDF Full ☐ EDD ☐ Date/Time Preserved with HNO3: 4/19/22 @ 16:20

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESER 0 = Ice 1 = HCl
VATIVE 2 = H2SO4 3 = NaOH
CODES 4 = HNO3 5 = Other

Print Name:	Signature:	Company:	Date + Time
SBonanno SEC Inc.	[Signature]	PAS	4/19/22 1:47 PM
Received: Lynn Souza	[Signature]		
Relinquished:			
Received:			
Relinquished:			
Received:			